

State Water Resources Control Board

September 25, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7017 2680 0000 6195 9357

Mr. Eric Lenhart
Chief Engineer
Urban Services Group, Inc.
95 Seventh Street, Section B-05
San Francisco, California 94103
eric.lenhart@urbanservicegroup.com

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT US GENERAL SERVICES ADMINISTRATION, 95 SEVENTH
STREET, SAN FRANCISCO**

Dear Mr. Lenhart:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on September 13, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Meet Designated Operator (DO) Requirements – The November 2017 monthly DO inspection report was not available at the time of inspection.	Diesel	November 1, 2017	November 30, 2017	23 CCR 2715(c)
2	Failure to Meet Designated Operator Requirements – The September 2017 monthly DO inspection was not available at the time of inspection.	Diesel	September 1, 2017	September 30, 2017	23 CCR 2715(c)
3	Failure to Provide Designated Operator Training – The DO employee training was due by August 31, 2018. The last training performed was August 18, 2017.	Diesel	September 1, 2018	Ongoing	23 CCR 2715(f)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, CA 95812-0100 | www.waterboards.ca.gov

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and San Francisco City & County Public Health Department within sixty (60) days from the date of this letter. Have your DO make specific notations in the next monthly DO report indicating the ongoing violations have been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov

Local CUPA

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County Public
Health Department
1390 Market Street, Suite 210
San Francisco, California 94102
jin.tang@sfdph.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Ms. Paula Stewart
Program Manager
San Francisco City & County
Public Health Department
paula.stewart@sfdph.org

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County
Public Health Department
jin.tang@sfdph.org